

ISBE ID	Building ID	Building Description	Sample Date	Sample Time (12 HR Clock)	Collected By	Sample ID	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Sample Volume (mL)	Laboratory Name	Analytical Method	Concentration (ug/L)	Reporting Limit (ug/L)	Notes
190220580022002	El Sierra	Elementary School	11/1/18	6:26 AM	DO	EL-01-A	NURSE OFFICE	S - Sink	10/31/18	7:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	4.39	2.00	
190220580022002	El Sierra	Elementary School	11/1/18	6:27 AM	DO	EL-01-B	NURSE OFFICE	S - Sink	10/31/18	7:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022002	El Sierra	Elementary School	11/1/18	6:28 AM	DO	EL-02-A	LOCATION 3 RIGHT SINK	S - Sink	10/31/18	7:01 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.68	2.00	
190220580022002	El Sierra	Elementary School	11/1/18	6:29 AM	DO	EL-02-B	LOCATION 3 RIGHT SINK	S - Sink	10/31/18	7:01 PM	Flush	250	ARRO Laboratory	EPA 200.5	10.60	2.00	
190220580022002	El Sierra	Elementary School	11/1/18	6:30 AM	DO	EL-04-A	LOCATION 9	S - Sink	10/31/18	7:04 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022002	El Sierra	Elementary School	11/1/18	6:31 AM	DO	EL-04-B	LOCATION 9	S - Sink	10/31/18	7:04 PM	Flush	250	ARRO Laboratory	EPA 200.5	3.79	2.00	
190220580022002	El Sierra	Elementary School	11/1/18	6:32 AM	DO	EL-05-A	LOCATION 14	S - Sink	10/31/18	7:05 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022002	El Sierra	Elementary School	11/1/18	6:32 AM	DO	EL-05-B	LOCATION 14	S - Sink	10/31/18	7:05 PM	Flush	250	ARRO Laboratory	EPA 200.5	4.06	2.00	
190220580022002	El Sierra	Elementary School	11/1/18	6:33 AM	DO	EL-06-A	LOCATION 17	S - Sink	10/31/18	7:06 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.00	2.00	
190220580022002	El Sierra	Elementary School	11/1/18	6:34 AM	DO	EL-06-B	LOCATION 17	S - Sink	10/31/18	7:06 PM	Flush	250	ARRO Laboratory	EPA 200.5	8.60	2.00	
190220580022002	El Sierra	Elementary School	11/1/18	6:35 AM	DO	EL-07-A	LOCATION 18	S - Sink	10/31/18	7:07 PM	First Draw	250	ARRO Laboratory	EPA 200.5	3.71	2.00	
190220580022002	El Sierra	Elementary School	11/1/18	6:36 AM	DO	EL-07-B	LOCATION 18	S - Sink	10/31/18	7:07 PM	Flush	250	ARRO Laboratory	EPA 200.5	5.99	2.00	
190220580022002	El Sierra	Elementary School	11/1/18	6:37 AM	DO	EL-08-A	LOCATION 21	S - Sink	10/31/18	7:08 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022002	El Sierra	Elementary School	11/1/18	6:38 AM	DO	EL-08-B	LOCATION 21	S - Sink	10/31/18	7:08 PM	Flush	250	ARRO Laboratory	EPA 200.5	19.80	2.00	
190220580022002	El Sierra	Elementary School	11/1/18	6:38 AM	DO	EL-09-A	LOCATION 22	S - Sink	10/31/18	7:09 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022002	El Sierra	Elementary School	11/1/18	6:39 AM	DO	EL-09-B	LOCATION 22	S - Sink	10/31/18	7:09 PM	Flush	250	ARRO Laboratory	EPA 200.5	20.50	2.00	
190220580022002	El Sierra	Elementary School	11/1/18	6:40 AM	DO	EL-10-A	LOCATION 25	S - Sink	10/31/18	7:10 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.00	2.00	
190220580022002	El Sierra	Elementary School	11/1/18	6:40 AM	DO	EL-10-B	LOCATION 25	S - Sink	10/31/18	7:10 PM	Flush	250	ARRO Laboratory	EPA 200.5	8.13	2.00	
190220580022002	El Sierra	Elementary School	11/1/18	6:30 AM	DO	EL-11-A	LOCATION 26	S - Sink	10/31/18	7:11 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022002	El Sierra	Elementary School	11/1/18	6:31 AM	DO	EL-11-B	LOCATION 26	S - Sink	10/31/18	7:11 PM	Flush	250	ARRO Laboratory	EPA 200.5	10.60	2.00	