

ISBE ID	Building ID	Building Description	Sample Date	Sample Time (12 HR Clock)	Collected By	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Sample Volume (mL)	Laboratory Name	Analytical Method	Concentration (ug/L)	Reporting Limit (ug/L)	Notes
190220580021014	Herrick	Elementary School	10/30/18	5:40 AM	JO	HE-01-A	Room 201 Middle	S - Sink	10/29/18	7:40 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.08	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:41 AM	JO	HE-01-B	Room 201 Middle	S - Sink	10/29/18	7:40 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:42 AM	JO	HE-02-A	Room 203	S - Sink	10/29/18	7:41 PM	First Draw	250	ARRO Laboratory	EPA 200.5	3.28	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:43 AM	JO	HE-02-B	Room 203	S - Sink	10/29/18	7:41 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:44 AM	JO	HE-03-A	Room 200	S - Sink	10/29/18	7:42 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:45 AM	JO	HE-03-B	Room 200	S - Sink	10/29/18	7:42 PM	Flush	250	ARRO Laboratory	EPA 200.5	10.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:46 AM	JO	HE-04-A	Outside 208/210 Left	DF - Drinking Fountain	10/29/18	7:43 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:46 AM	JO	HE-04-B	Outside 208/210 Left	DF - Drinking Fountain	10/29/18	7:43 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:47 AM	JO	HE-05-A	Outside 208/210 Right	DF - Drinking Fountain	10/29/18	7:45 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:47 AM	JO	HE-05-B	Outside 208/210 Bottle Fill Right	O - Other	10/29/18	7:45 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:47 AM	JO	HE-06-A	Outside 208/210 Right	DF - Drinking Fountain	10/29/18	7:45 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:49 AM	JO	HE-07-A	Room 213 #5	S - Sink	10/29/18	7:47 PM	First Draw	250	ARRO Laboratory	EPA 200.5	5.18	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:50 AM	JO	HE-07-B	Room 213 #5	S - Sink	10/29/18	7:47 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:51 AM	JO	HE-08-A	Nurse	S - Sink	10/29/18	7:50 PM	First Draw	250	ARRO Laboratory	EPA 200.5	5.12	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:51 AM	JO	HE-08-B	Nurse	S - Sink	10/29/18	7:50 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:52 AM	JO	HE-09-A	Band Room	S - Sink	10/29/18	7:51 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.28	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:52 AM	JO	HE-09-B	Band Room	S - Sink	10/29/18	7:51 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.12	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:53 AM	JO	HE-10-A	Boy's Locker Room	S - Sink	10/29/18	7:52 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.27	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:53 AM	JO	HE-10-B	Boy's Locker Room	S - Sink	10/29/18	7:52 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.26	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:55 AM	JO	HE-11-A	Near 112 Left	DF - Drinking Fountain	10/29/18	7:55 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:56 AM	JO	HE-11-B	Near 112 Left	DF - Drinking Fountain	10/29/18	7:55 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:57 AM	JO	HE-12-A	Near 112 Right	DF - Drinking Fountain	10/29/18	7:56 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:58 AM	JO	HE-12-B	Near 112 Bottle Fill	O - Other	10/29/18	7:56 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	5:58 AM	JO	HE-13-A	Near 112 Right	DF - Drinking Fountain	10/29/18	7:58 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	6:00 AM	JO	HE-14-A	Near 108 Left	DF - Drinking Fountain	10/29/18	7:58 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.01	2.00	
190220580021014	Herrick	Elementary School	10/30/18	6:00 AM	JO	HE-14-B	Near 108 Left	DF - Drinking Fountain	10/29/18	7:59 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	6:01 AM	JO	HE-15-A	Near 108 Right	DF - Drinking Fountain	10/29/18	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	6:01 AM	JO	HE-15-B	Near 108 Bottle Fill	O - Other	10/29/18	8:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	6:02 AM	JO	HE-16-A	Near 108 Right	DF - Drinking Fountain	10/29/18	8:05 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	6:03 AM	JO	HE-17-A	Room 105	S - Sink	10/29/18	8:05 PM	First Draw	250	ARRO Laboratory	EPA 200.5	4.25	2.00	
190220580021014	Herrick	Elementary School	10/30/18	6:04 AM	JO	HE-17-B	Room 105	S - Sink	10/29/18	8:06 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.23	2.00	
190220580021014	Herrick	Elementary School	10/30/18	6:06 AM	JO	HE-18-A	Room 102	S - Sink	10/29/18	8:06 PM	First Draw	250	ARRO Laboratory	EPA 200.5	5.01	2.00	
190220580021014	Herrick	Elementary School	10/30/18	6:07 AM	JO	HE-18-B	Room 102	S - Sink	10/29/18	8:08 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	6:08 AM	JO	HE-19-A	Room 103	S - Sink	10/29/18	8:08 PM	First Draw	250	ARRO Laboratory	EPA 200.5	8.42	2.00	
190220580021014	Herrick	Elementary School	10/30/18	6:09 AM	JO	HE-19-B	Room 103	S - Sink	10/29/18	7:59 PM	Flush	250	ARRO Laboratory	EPA 200.5	8.42	2.00	
190220580021014	Herrick	Elementary School	10/30/18	6:10 AM	JO	HE-20-A	Room 101	S - Sink	10/29/18	7:59 PM	First Draw	250	ARRO Laboratory	EPA 200.5	8.12	2.00	
190220580021014	Herrick	Elementary School	10/30/18	6:11 AM	JO	HE-20-B	Room 101	S - Sink	10/29/18	7:55 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	6:12 AM	JO	HE-21-A	Outside Room 101	DF - Drinking Fountain	10/29/18	7:55 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	6:13 AM	JO	HE-21-B	Outside Room 101 Bottle Fill	O - Other	10/29/18	7:56 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021014	Herrick	Elementary School	10/30/18	6:14 AM	JO	HE-22-A	Outside Room 101	DF - Drinking Fountain	10/29/18	7:56 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	