

ISBE ID	Building ID	Building Description	Sample Date	Sample Time (12 HR Clock)	Collected By	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Sample Volume (mL)	Laboratory Name	Analytical Method	Concentration (ug/L)	Reporting Limit (ug/L)	Notes
190220580021015	O'Neill	Middle School	10/31/18	5:30 AM	DO	O-01-A	Boys Locker Room	DF - Drinking Fountain	10/30/18	7:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:31 AM	DO	O-01-B	Boys Locker Room	DF - Drinking Fountain	10/30/18	7:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:35 AM	DO	O-02-A	Faculty Lounge	S - Sink	10/30/18	7:01 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:36 AM	DO	O-02-B	Faculty Lounge	S - Sink	10/30/18	7:01 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:37 AM	DO	O-03-A	Corridor at Faculty Lounge	DF - Drinking Fountain	10/30/18	7:04 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:37 AM	DO	O-03-B	Corridor at Faculty Lounge	DF - Drinking Fountain	10/30/18	7:04 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:38 AM	DO	O-03-A2	Bottle Fill Outside of Faculty Lounge	O - Other	10/30/18	7:05 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:38 AM	DO	O-04-A	Room 147	S - Sink	10/30/18	7:05 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:39 AM	DO	O-04-B	Room 147	S - Sink	10/30/18	7:05 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:40 AM	DO	O-05-A	Room 149 Stainless Steel Right	S - Sink	10/30/18	7:06 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:40 AM	DO	O-05-B	Room 149 Stainless Steel Right	S - Sink	10/30/18	7:06 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:41 AM	DO	O-06-A	Room 149 Porcelain	S - Sink	10/30/18	7:07 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:41 AM	DO	O-06-B	Room 149 Porcelain	S - Sink	10/30/18	7:07 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:42 AM	DO	O-07-A	Main Office Work Room	S - Sink	10/30/18	7:08 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:42 AM	DO	O-07-B	Main Office Work Room	S - Sink	10/30/18	7:08 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:43 AM	DO	O-08-A	Room 112	S - Sink	10/30/18	7:09 PM	Flush	250	ARRO Laboratory	EPA 200.5	5.68	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:43 AM	DO	O-08-B	Room 112	S - Sink	10/30/18	7:09 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:44 AM	DO	O-09-A	Room 113	S - Sink	10/30/18	7:10 PM	Flush	250	ARRO Laboratory	EPA 200.5	6.21	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:45 AM	DO	O-09-B	Room 113	S - Sink	10/30/18	7:10 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:46 AM	DO	O-10-A	Room 110	S - Sink	10/30/18	7:11 PM	Flush	250	ARRO Laboratory	EPA 200.5	7.98	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:51 AM	DO	O-10-B	Room 110	S - Sink	10/30/18	7:13 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:52 AM	DO	O-11-A	Room 111	S - Sink	10/30/18	7:13 PM	Flush	250	ARRO Laboratory	EPA 200.5	3.37	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:53 AM	DO	O-11-B	Room 111	S - Sink	10/30/18	7:14 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:53 AM	DO	O-12-A	Corridor at 126	DF - Drinking Fountain	10/30/18	7:14 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.19	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:54 AM	DO	O-12-B	Corridor at 126	DF - Drinking Fountain	10/30/18	7:15 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:55 AM	DO	O-12-A2	Corridor at 126 Bottle Fill	O - Other	10/30/18	7:16 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:55 AM	DO	O-13-A	Band Room	S - Sink	10/30/18	7:16 PM	Flush	250	ARRO Laboratory	EPA 200.5	3.63	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:56 AM	DO	O-13-B	Band Room	S - Sink	10/30/18	7:16 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.53	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:56 AM	DO	O-14-A	Band Room	DF - Drinking Fountain	10/30/18	7:17 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.88	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:57 AM	DO	O-14-B	Band Room	DF - Drinking Fountain	10/30/18	7:17 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.67	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:58 AM	DO	O-15-A	Fitness Room	DF - Drinking Fountain	10/30/18	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:59 AM	DO	O-15-B	Fitness Room	DF - Drinking Fountain	10/30/18	7:18 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.63	2.00	
190220580021015	O'Neill	Middle School	10/31/18	5:59 AM	DO	O-16-A	Room 132	S - Sink	10/30/18	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	7.02	2.00	
190220580021015	O'Neill	Middle School	10/31/18	6:00 AM	DO	O-16-B	Room 132	S - Sink	10/30/18	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	6:05 AM	DO	O-17-A	137 Work Room	S - Sink	10/30/18	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	4.43	2.00	
190220580021015	O'Neill	Middle School	10/31/18	6:06 AM	DO	O-17-B	137 Work Room	S - Sink	10/30/18	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.34	2.00	
190220580021015	O'Neill	Middle School	10/31/18	6:07 AM	DO	O-18-A	Multi Purpose Room	DF - Drinking Fountain	10/30/18	7:18 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	6:08 AM	DO	O-18-B	Multi Purpose Room	O - Other	10/30/18	7:18 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	6:12 AM	DO	O-18-A2	Multi Purpose Room	DF - Drinking Fountain	10/30/18	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	6:12 AM	DO	O-19-A	Hand Sink Kitchen	S - Sink	10/30/18	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	6:13 AM	DO	O-19-B	Hand Sink Kitchen	S - Sink	10/30/18	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	7.07	2.00	
190220580021015	O'Neill	Middle School	10/31/18	6:15 AM	DO	O-20-A	Prep Sink Kitchen	S - Sink	10/30/18	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	6:17 AM	DO	O-20-B	Prep Sink Kitchen	S - Sink	10/30/18	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	6:20 AM	DO	O-21-A	Room 200 Left Double Sink Right Fixture	S - Sink	10/30/18	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	6:20 AM	DO	O-21-B	Room 200 Left Double Sink Right Fixture	S - Sink	10/30/18	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.33	2.00	
190220580021015	O'Neill	Middle School	10/31/18	6:21 AM	DO	O-22-A	Corridor at Room 205	DF - Drinking Fountain	10/30/18	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	6:22 AM	DO	O-22-B	Corridor at Room 205	DF - Drinking Fountain	10/30/18	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	6:23 AM	DO	O-23-A	Room 211	S - Sink	10/30/18	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	6:24 AM	DO	O-23-B	Room 211	S - Sink	10/30/18	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	7.03	2.00	
190220580021015	O'Neill	Middle School	10/31/18	6:26 AM	DO	O-24-A	Room 212	S - Sink	10/30/18	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	6:27 AM	DO	O-24-B	Room 212	S - Sink	10/30/18	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	3.28	2.00	
190220580021015	O'Neill	Middle School	10/31/18	6:30 AM	DO	O-25-A	Room 213	S - Sink	10/30/18	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580021015	O'Neill	Middle School	10/31/18	6:31 AM	DO	O-25-B	Room 213	S - Sink	10/30/18	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	17.20	2.00	
190220580021015	O'Neill	Middle School	10/31/18	6:32 AM	DO	O-26-A	Room 214	S - Sink	10/30/18	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.62	2.00	
190220580021015	O'Neill	Middle School	10/31/18	6:33 AM	DO	O-26-B	Room 214	S - Sink	10/30/18	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	4.91	2.00	