ISBE ID	Building ID	Building Description	Sample Date	Sample Time (12 HR Clock)	Collected By	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Sample Volume (mL)	Laboratory Name	Analytical Method	Concentration (ug/L)	Reporting Limit (ug/L)	Notes
190220580022005	Hillcrest	Elementary School	4/19/18	6:19 AM	DO	HC01A	Room 3	S - Sink	4/18/18	7:04 PM	First Draw	250	ARRO Laboratory	EPA 200.5	6.20	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:19 AM	DO	HC01B	Room 3	S - Sink	4/18/18	7:04 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:20 AM	DO	HC02A	Room 1	S - Sink	4/18/18	7:06 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:20 AM	DO	HC02B	Room 1	S - Sink	4/18/18	7:06 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:22 AM	DO	HC03A	LRC Work room	S - Sink	4/18/18	7:10 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:22 AM	DO	HC03B	LRC Work room	S - Sink	4/18/18	7:10 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:25 AM	DO	HC04A	Room 5	S - Sink	4/18/18	7:11 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:25 AM	DO	HC04B	Room 5	S - Sink	4/18/18	7:11 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:26 AM	DO	HC05A	Room 7	S - Sink	4/18/18	7:13 PM	First Draw	250	ARRO Laboratory	EPA 200.5	5.40	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:26 AM	DO	HC05B	Room 7	S - Sink	4/18/18	7:13 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:28 AM	DO	HC06A	Room 9	S - Sink	4/18/18	7:16 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:28 AM	DO	HC06B	Room 9	S - Sink	4/18/18	7:16 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:30 AM	DO	HC07A	Room 10	S - Sink	4/18/18	7:17 PM	First Draw	250	ARRO Laboratory	EPA 200.5	3.53	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:30 AM	DO	HC07B	Room 10	S - Sink	4/18/18	7:17 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:32 AM	DO	HC08A	Room 17	S - Sink	4/18/18	7:27 PM	First Draw	250	ARRO Laboratory	EPA 200.5	4.21	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:32 AM	DO	HC08B	Room 17	S - Sink	4/18/18	7:27 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:33 AM	DO	HC09A	Room 18	S - Sink	4/18/18	7:28 PM	First Draw	250	ARRO Laboratory	EPA 200.5	2.39	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:33 AM	DO	HC09B	Room 18	S - Sink	4/18/18	7:28 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:34 AM	DO	HC10A	Outside 18	F - Water Cooler	4/18/18	7:29 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:34 AM	DO	HC10B	Outside 18	F - Water Cooler	4/18/18	7:29 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:35 AM	DO	HC11A	Room 19	S - Sink	4/18/18	7:30 PM	First Draw	250	ARRO Laboratory	EPA 200.5	4.26	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:35 AM	DO	HC11B	Room 19	S - Sink	4/18/18	7:30 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:37 AM	DO	HC12A	Room 22	S - Sink	4/18/18	7:32 PM	First Draw	250	ARRO Laboratory	EPA 200.5	28.50	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:37 AM	DO	HC12B	Room 22	S - Sink	4/18/18	7:32 PM	Flush	250	ARRO Laboratory	EPA 200.5	31.90	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:38 AM	DO	HC13A	Room 23	S - Sink	4/18/18	7:35 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:38 AM	DO	HC13B	Room 23	S - Sink	4/18/18	7:35 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:39 AM	DO	HC14A	Room 24	S - Sink	4/18/18	7:36 PM	First Draw	250	ARRO Laboratory	EPA 200.5	39.00	2.00	
190220580022005	Hillcrest	Elementary School	4/19/18	6:39 AM	DO	HC14B	Room 24	S - Sink	4/18/18	7:36 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	