

El Sierra Elementary School 6835 Fairmount Ave Downers Grove, IL

ISBE ID	Sample	Sample	Sample ID	Sample Location Description	Fixture Type	Date of Last	Time of	Sample	Concentration
	6/1/2023	7:24:00 AM	ESES01A	Gymnasium vestibule - by boiler	DF - Drinking Fountain	5/31/2023	6:21 PM	First Draw	<2.0 µg/L
	6/1/2023	7:24:00 AM	ESES01B	Gymnasium vestibule - by boiler	BF - Bottle Filler	5/31/2023	6:21 PM	First Draw	<2.0 µg/L
	6/1/2023	7:24:00 AM	ESES01C	Gymnasium vestibule - by boiler	DF - Drinking Fountain	5/31/2023	6:21 PM	Flush	<2.0 µg/L
	6/1/2023	7:24:00 AM	ESES02A	Gymnasium vestibule - by kitchen	DF - Drinking Fountain	5/31/2023	6:22 PM	First Draw	<2.0 µg/L
	6/1/2023	7:24:00 AM	ESES02B	Gymnasium vestibule - by kitchen	BF - Bottle Filler	5/31/2023	6:22 PM	First Draw	<2.0 µg/L
	6/1/2023	7:24:00 AM	ESES02C	Gymnasium vestibule - by kitchen	DF - Drinking Fountain	5/31/2023	6:22 PM	Flush	<2.0 µg/L
	6/1/2023	7:26:00 AM	ESES03A	By door 9	DF - Drinking Fountain	5/31/2023	6:18 PM	First Draw	<2.0 µg/L
	6/1/2023	7:26:00 AM	ESES03B	By door 9	DF - Drinking Fountain	5/31/2023	6:18 PM	Flush	<2.0 µg/L
	6/1/2023	7:37:00 AM	ESES04A	By door 2	DF - Drinking Fountain	5/31/2023	6:14 PM	First Draw	<2.0 µg/L
	6/1/2023	7:37:00 AM	ESES04B	By door 2	DF - Drinking Fountain	5/31/2023	6:14 PM	Flush	<2.0 µg/L
	6/1/2023	7:38:00 AM	ESES05A	Outside office	DF - Drinking Fountain	5/31/2023	6:15 PM	First Draw	<2.0 µg/L
	6/1/2023	7:38:00 AM	ESES05B	Outside office	DF - Drinking Fountain	5/31/2023	6:15 PM	Flush	<2.0 µg/L