


Whittier Elementary School 536 Hill St. Downers Grove, IL

ISBE ID	Sample	Sample	Sample ID	Sample Location Description	Fixture Type	Date of Last	Time of	Sample	Concentration
	5/31/2023	5:44AM	WH01A	HW outside CR1	DF - Drinking Fountain	5/30/2023	6:04PM	First Draw	<2.0 µg/L
	5/31/2023	5:44AM	WH01B	HW outside CR1	DF - Drinking Fountain	5/30/2023	6:04PM	Flush	<2.0 µg/L
	5/31/2023	5:45AM	WH02A	HW outside CR4	DF - Drinking Fountain	5/30/2023	6:08PM	First Draw	<2.0 µg/L
	5/31/2023	5:45AM	WH02B	HW outside CR4	BF - Bottle Filler	5/30/2023	6:08PM	First Draw	<2.0 µg/L
	5/31/2023	5:45AM	WH02C	HW outside CR4	DF - Drinking Fountain	5/30/2023	6:08PM	Flush	<2.0 µg/L
	5/31/2023	5:48AM	WH03A	HW outside CR8	DF - Drinking Fountain	5/30/2023	6:13PM	First Draw	<2.0 µg/L
	5/31/2023	5:48AM	WH03B	HW outside CR8	BF - Bottle Filler	5/30/2023	6:13PM	First Draw	<2.0 µg/L
	5/31/2023	5:48AM	WH03C	HW outside CR8	DF - Drinking Fountain	5/30/2023	6:13PM	Flush	<2.0 µg/L
	5/31/2023	5:50AM	WH04A	CR1	S - Sink	5/30/2023	6:00PM	First Draw	<2.0 µg/L
	5/31/2023	5:50AM	WH04B	CR1	S - Sink	5/30/2023	6:00PM	Flush	<2.0 µg/L
	5/31/2023	5:53AM	WH05A	CR2	S - Sink	5/30/2023	6:02PM	First Draw	<2.0 µg/L
	5/31/2023	5:53AM	WH05B	CR2	S - Sink	5/30/2023	6:02PM	Flush	<2.0 µg/L
	5/31/2023	5:55AM	WH06A	CR4	S - Sink	5/30/2023	6:06PM	First Draw	<2.0 µg/L
	5/31/2023	5:55AM	WH06B	CR4	S - Sink	5/30/2023	6:06PM	Flush	<2.0 µg/L
	5/31/2023	5:57AM	WH07A	CR5	S - Sink	5/30/2023	6:10PM	First Draw	2.2 µg/L
	5/31/2023	5:57AM	WH07B	CR5	S - Sink	5/30/2023	6:10PM	Flush	<2.0 µg/L
	5/31/2023	6:00AM	WH08A	HW outside kitchen	DF - Drinking Fountain	5/30/2023	6:22PM	First Draw	<2.0 µg/L
	5/31/2023	6:00AM	WH08B	HW outside kitchen	BF - Bottle Filler	5/30/2023	6:22PM	First Draw	<2.0 µg/L
	5/31/2023	6:00AM	WH08C	HW outside kitchen	DF - Drinking Fountain	5/30/2023	6:22PM	Flush	<2.0 µg/L
	5/31/2023	6:03AM	WH09A	Kitchen	S - Sink	5/30/2023	6:20PM	First Draw	<2.0 µg/L
	5/31/2023	6:03AM	WH09B	Kitchen	S - Sink	5/30/2023	6:20PM	Flush	<2.0 µg/L
	5/31/2023	6:05AM	WH10A	HW outside CR 19	DF - Drinking Fountain	5/30/2023	6:30PM	First Draw	<2.0 µg/L
	5/31/2023	6:05AM	WH10C	HW outside CR 19	DF - Drinking Fountain	5/30/2023	6:30PM	Flush	<2.0 µg/L
	5/31/2023	6:09AM	WH11A	Left fountain - HW outside CR15	DF - Drinking Fountain	5/30/2023	6:32PM	First Draw	<2.0 µg/L
	5/31/2023	6:09AM	WH11B	Left fountain - HW outside CR15	DF - Drinking Fountain	5/30/2023	6:32PM	Flush	<2.0 µg/L
	5/31/2023	6:10AM	WH12A	Right fountain - HW outside CR15	DF - Drinking Fountain	5/30/2023	6:34PM	First Draw	<2.0 µg/L
	5/31/2023	6:10AM	WH12B	Right fountain - HW outside CR15	DF - Drinking Fountain	5/30/2023	6:34PM	Flush	<2.0 µg/L
	5/31/2023	6:12AM	WH13A	CR14	S - Sink	5/30/2023	6:24PM	First Draw	<2.0 µg/L
	5/31/2023	6:12AM	WH13B	CR14	S - Sink	5/30/2023	6:24PM	Flush	<2.0 µg/L



Not on drawing, no handwash plaque, sticky note present