SCHOOL BUILDING: Longfellow Maintenance Center		NAME OF INSPECTOR:	Thad Daniels	
SCHOOL ID NUMBER:		SIGNATURE:		
DATE OF INSPECTION:	May 12, 2021	ACCREDITATION NUMBER AN	ND STATE:	100-01306

					CURRENT KNOWN / ASSUMED ACBM					
SAMPLE AREA DESIGNATION	ACBM IDENTIFIED	ROOMS INCLUDED IN AREA	ORIGINAL AHERA CATEGORY	CHANGE IN CONDITION		1 AHFRA I		NEW AHERA CATEGORY		
				NO	YES	NO	YES			
IDPH-8	Pipe Insulation	Boiler Room & Basement	5		Х		Х	0 Abated		
IDPH-9	Pipe Fittings	Boiler Room & Basement	5		Х		Х	0 Abated		
IDPH-10	Boiler Insulation	Boiler Room	5		Х		Х	0 Abated		
FT-2	9" X 9" Marbled Floor Tile	Various Locations Throughout	8	Х		Х		8		
FT-4	9" X 9" Streaked Floor Tile	Various Locations Throughout	8	Х		Х		8		
FT-5	Floor Tile below Carpet	Throughout School	8	Х		Х		8		
СВ	Chalkboards & Adhesive	Boardroom & Maintenance Office	8	Х		Х		8		
PIF - A	Pipe Insulation & Fittings	Attic	8	Х		Х		8		
AI - A	Attic Insulation	Attic	8	Х		Х		8		

PERSON PERFORMING REASSESSMENTS		
NAME	SIGNATURE	ACCREDITATION NUMBER AND STATE
Thad Daniels		100-01306

SCHOOL BUILDING: Longfellow Maintenance Center		NAME OF INSPECTOR:	Thad Daniels
SCHOOL ID NUMBER:		SIGNATURE:	
DATE OF INSPECTION:	M ay 12, 2021	ACCREDITATION NUMBER AND STA	TE: 100-001306

				C	URRE	NT KN	N / NWC	ASSUMED ACBM
SAMPLE AREA DESIGNATION	ACBM IDENTIFIED	ROOMS INCLUDED IN AREA	ORIGINAL AHERA CATEGORY	CHANGE IN CONDITION		CHANGE IN AHERA CATEGORY		NEW AHERA CATEGORY
				NO	YES	NO	YES	
FB	Fire Brick	Boiler Room	8 Assumed	Х		Х		8 Assumed
FD	Fire Doors	Storage Room	8 Assumed	Х		Х		8 Assumed
FTA	Floor Tile Mastic	Throughout School	8	Х		Х		8
ws	Window Sills	Various Locations	8 Assumed	Х		Х		8 Assumed
TPA	Dampener Gaskets	Throughout Building	8 Assumed	Х		Х		8 Assumed
MFA	12"x12" Floor Tile/Mastic	Office Lounge	8 Assumed	Х		Х		8 Assumed
ТРА	Pipe Insulation Materials	Assumed - Concelaed in Non-Accessible Areas	8 Assumed	Х		Х		8 Assumed
TJA	Hard Fittings on Piping	Assumed - Concelaed in Non-Accessible Areas	8 Assumed	Х		Х		8 Assumed

PERSON PERFORMING REASSESSMENTS		
NAME	SIGNATURE	ACCREDITATION NUMBER AND STATE
Thad Daniels		100-02620